



CITY OF YORK, PENNSYLVANIA

DEPARTMENT OF FIRE/RESCUE SERVICES

FIRE PREVENTION BUREAU

43 S. DUKE STREET, YORK, PA 17401

www.yorkcity.org

HONORABLE C. KIM BRACEY, MAYOR

GAMEWELL FIRE ALARM INSTALLATION INFORMATION SHEET

Whenever a fire detection or fire suppression system is required in any building, it shall be connected to the City's Gamewell Municipal Fire Alarm System.

Installer of the system shall contact the Department of Fire/Rescue Services to obtain code wheel number assignment and box location.

One (1) Gamewell M34-110 Local Energy Master Box with plain door (no public access) and weatherproof cottage shell. DO NOT SUBSTITUTE.

The installer shall deliver the Gamewell Box and keys to the Electrical Bureau at 1625 Toronita Street to be checked for timing prior to installation.

The installer shall contact the Fire Prevention Office or Electrical Bureau to schedule a site visit for specific mounting location of the Gamewell Box, weatherhead, and through clevis attachment point.

The above box to be mounted on exterior wall surface at location specified by the City of York and may be painted any color by the owner.

The installer shall contact the Electrical Bureau for final connections.

The following are general specifications and equipment requirements for Gamewell Box installations.

- 1. The Gamewell Box shall be mounted at a height of 5 and ½ feet from finished grade to the center of the Box.*
- 2. An insulated through-bolted clevis shall be installed at the specified height for the attachment of the municipal alarm wires.*
- 3. Two (2) #12 solid conductors shall be supplied from the Gamewell Box with a minimum of 18" extending through the weatherhead for final connection.*
- 4. A #12 solid grounding wire shall be provided from the Gamewell Box to a driven or cold water pipe ground.*
- 5. Installation fee: \$200.00 plus \$75.00 per hour for labor, plus cost of materials.*

Contact the following for information prior to installation.

Principal Contacts

Fire: 717/854-3921

Electrical: 717/845-9351

**David P. Michaels, Acting Chief
Chad A. Deardorff, Deputy Chief
Gil A. Kimes, Assistant Chief**

**Dave Rudolph, Superintendent
Roy Wolfhope, Technician**

Revised 7/26/17

Telephone: 717/854-3921

Facsimile: 717/843-0464