

Council of City of York, PA

Session 2019

Resolution No. 30

*Judy A. Ritter-Dickson*

INTRODUCED BY: **Judy A. Ritter-Dickson**

DATE: **April 16, 2019**

WHEREAS, York Catholic High School has submitted a stormwater management site plan associated with improvements to its athletic fields; and

WHEREAS, the City Planner and City Engineer have reviewed the site plan for consistency with Article 937 of the York City Codified Ordinances, related to Stormwater Management Standards; and

WHEREAS, in order to ensure a property owner's ability to maintain the side slopes of a stormwater basin with a riding lawnmower, Article 937 Section 9.C.1.f permits a maximum side slope in a stormwater basin of 4 horizontal to 1 vertical; and

WHEREAS, the City Engineer has made York Catholic High School aware of the requirement and intention of the ordinance; and

WHEREAS, York Catholic High School has requested a waiver from §937.9.C.1.f to construct a stormwater basin with side slopes steeper than the maximum slope permitted; and

WHEREAS, York Catholic High School currently maintains slopes elsewhere on its property that are steeper than the proposed stormwater basin; and

WHEREAS, York Catholic High School accepts maintenance responsibilities for the proposed stormwater basin; and

THEREFORE, the City Planner and City Engineer recommend approval of the requested waiver;

NOW, THEREFORE, BE IT RESOLVED, by the Council of the City of York, Pennsylvania that York Catholic High School, located at 601 East Springettsbury Avenue, is granted a waiver from Article 937 Section 9.C.1.f of the Codified Ordinances of the City of York for the stormwater management site plan associated with improvements to its athletic fields.

PASSED FINALLY: **April 16, 2019**

BY THE FOLLOWING VOTE:

YEAS: Washington, Ritter-Dickson, Buckingham, Walker - 4

NAYS: None

*Sandie Walker*  
Sandie Walker, Vice President of Council

ATTEST:

*Dianna L. Thompson-Mitchell*  
Dianna L. Thompson-Mitchell, City Clerk